

## EXHIBIT B

## CONSUMER CONFIDENCE REPORT DETECTION LEVELS (CCRD L)

	Constituent	CCRD L, ng/L
1	PERFLUOROBUTANESULFONIC ACID (PFBS)	4
2	PERFLUORONONANOIC ACID (PFNA)	4
3	PERFLUORODECANOIC ACID (PFDA)	4
4	PERFLUOROTETRADECANOIC ACID (PFTA)	4
5	HEXAFLUOROPROPYLENE OXIDE DIMER ACID (HFPO-DA)	4
6	4,8-DIOXA-3H-PERFLUORONONANOIC ACID (ADONA)	2
7	PERFLUOROHEPTANOIC ACID (PFHpA)	4
8	N-ETHYL PERFLUOROOCTANESULFONAMIDOACETIC ACID	4
9	PERFLUORODODECANOIC ACID (PFD <sub>o</sub> A)	4
10	PERFLUOROTRIDECANOIC ACID (PFT <sub>r</sub> DA)	4
11	9-CHLOROHEXADECAFLUORO-3-OXANONE-1-SULFONIC ACID	2
12	PERFLUOROOCTANE SULFONIC ACID (PFOS)	4
13	PERFLUOROHEXANE SULFONIC ACID (PFH <sub>x</sub> S)	4
14	N-METHYL PERFLUOROOCTANESULFONAMIDOACETIC ACID	4
15	PERFLUOROHEXANOIC ACID (PFH <sub>x</sub> A)	4
16	PERFLUOROUNDECANOIC ACID (PFUnA)	4
17	11-CHLOROEICOSAFLUORO-3-OXAUNDECANE-1-SULFONIC ACID	2
18	PERFLUOROOCTANOIC ACID (PFOA)	4

## NOTES:

1. The CCRDL is based on a review of the reporting levels reported for monitoring conducted between August and December 2019. Specifically, the SWB calculated the CCRDL as the reporting level that was achievable in 90 percent of all negative result reported during that period. Results were rounded to the nearest whole number.
2. For HFPO-DA, the rounded CCRDL is lower than the 90<sup>th</sup> percentile of conveyed reporting levels based on consultation with the laboratory reporting the highest volume of results, and their statement that a reporting level of 4 ng/L (4 ppt) could readily be achieved.